

TEST REPORT

Report A/LR No : TC843322000000099F
Sample Receipt Date : 11.02.2022
Analysis Date : 11.02.2022 to 15.02.2022
Date of Report Issue : 15.02.2022
Customer Ref No / Date : NV WATER SOLUTION

Sample Code No : AWQRC/02/22/099
Sample Description : Water
Quantity : 1 litre
Sample Condition : Satisfactory & Sealed
Sample Type : Water Sample (RO)
Sample Detail : Marked As Drinking Water

ISSUED TO:-
MAMTA SR. SEC PUBLIC SCHOOL
H Block, Vikaspuri,
New Delhi-110016

TEST RESULTS

| PARAMETER TESTED | | | IS: 10500-2012 Drinking Water Specification (Second Revision) | | |
|------------------|--|-------|---|-----------------------------------|------------------------|
| Sl No | PHYSICO-CHEMICAL | UNITS | RESULT | REQUIREMENT (Acceptable Limit) | TEST METHOD |
| 1. | Turbidity | NTU | BDL(DL=0.1) | 1 | IS:3025 (Part 10)-1984 |
| 2. | pH value | - | 7.42 | 6.5-8.5 | IS:3025 (Part 11)-1983 |
| 3. | Total Dissolved Solids | mg/l | 85 | 500 | IS:3025 (Part 16)-1984 |
| 4. | Total Hardness as CaCO ₃ | mg/l | 36 | 200 | IS:3025 (Part 21)-2009 |
| 5. | Calcium as Ca ⁺⁺ | mg/l | 9.6 | 75 | IS:3025 (Part 40)-1991 |
| 6. | Magnesium as Mg ⁺⁺ | mg/l | 2.9 | 30 | IS:3025 (Part 46)-1994 |
| 7. | Total Alkalinity as CaCO ₃ | mg/l | 28 | 200 | IS:3025 (Part 23)-1986 |
| 8. | Chloride as Cl ⁻ | mg/l | 24 | 250 | IS:3025 (Part 32)-1988 |
| 9. | Free Residual Chlorine | mg/l | BDL(DL=0.2) | 0.2 | IS:3025 (Part 26)-2021 |
| 10. | Sulphate as SO ₄ ⁻ | mg/l | 7.0 | 200 | IS:3025 (Part 24)-1986 |

BDL= Below Detection Limit DL=Detection Limit.

Remarks -

- 1) The Above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- 2) The results relate to item tested.

Lab Address :

C-348, 3rd Floor, Ramphal Chowk
Sector 7, Dwarka, New Delhi
Mob No: 9868911295, 01141608075

Corporate Office
B1/B2, 701, Marathon Innova, Off Ganpatrao Kadam Marg,
Lower Parel, Mumbai - 400013, India
Phone : +91-22-62601888, 48821700 / 09 / 13

Page 1 of 1

Regd. Office
7, Chakrabarti Road (South)
Kolkata-700025, India
Phone : +91-33-24755400


Website : <http://www.eurekaforbes.com>

Water Quality Manager



SOUTH DELHI MUNICIPAL CORPORATION
PUBLIC HEALTH DEPARTMENT, WEST ZONE

Vishal Enclave, Rajouri Garden, New Delhi - 110027



No. D-881/HD/W2

Dated: 02/07/19

Health Certificate

1. Name of the school Mamta Modern Sr. Sec. School.
2. School address A Block Vikash Puri New Delhi 110018
3. No of shifts I Timings: 8.00 to 2.00 PM
4. No. of students :-Boys 1301 Girls 944 Total 2245
5. No. of staff:- Gents 26 Ladies 83 Total 109.

Accommodation provided for classroom as under:-

- Floor area in the classroom is sufficient / insufficient Sufficient.
Classes are well lighted / ill lighted well lighted.
Classrooms are well ventilated / ill ventilated well ventilated
Classes are kept / not kept neat and clean neat & Clean
Building / classrooms require / do not require white wash etc. Do not required.
Drinking water is wholesome / not wholesome not wholesome
Latrine arrangement is sanitary / insanitary good Sanitary Conditions

No. of toilets seats for students

- One latrine-cum-urinal is required for 25 female students, so total is Sufficient
One latrine for 40 male students is required, so total is Sufficient
Separate toilet arrangement for staff yes/ no Yes
The overall facilities good / adequate / inadequate good.
valid up to 1 year from issued date.

If Building Department or any other Govt agency takes action against u/a construction or any dispute, then the Health Certificate will be stand cancelled / revoked without any further intimation in this regard.

Dy Health Officer
Dr SAURABH MISHRA
West Zone
MBBS, M D
Dy Health Officer
West Zone